CERTIFICATE OF COMPLIANCE

Certificate Number	20151124-E225710
Report Reference	E225710-20021004
Issue Date	2015-NOVEMBER-24

Issued to:	SIEMENS SWITZERLAND LTD GUBELSTRASSE 22 CH-6301 ZUG SWITZERLAND
This is to certify that representative samples of	FLAME-AUTOMATIC FIRE DETECTORS FOR USE IN HAZARDOUS LOCATIONS; FLAME DETECTORS, FIRE ALARM, FOR USE IN HAZARDOUS LOCATIONS Intrinsically safe flame detector, Model DF1101-Ex for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G and Class III Hazardous Locations when installed in accordance with control drawing SM303.
	Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations CAN/CSA C22.2 No. 157-92, Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations
Additional Information:	See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/