

WSPCert Certificate

No. BAC-0210-01

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2014. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The 12 BACnet Application Specific Controllers (B-ASC)

**DXR2.M11 (101A, 101B),
DXR2.E12P/DXR2.M12P (102A, 102B),
DXR2.E18/DXR2.M18 (101A, 102A, 101B)**

with the software version:

**FW=01.20.54.247;WPC=1.2.2002;
SVS-300;SBC=13.20**

of

Siemens Schweiz AG

Gubelstrasse 22, 6301 Zug, Switzerland

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 14.0 and the Certification Rules of the BACnet Interest Group Europe, see **SoftDEL Test Report No. TC50635 and TC50702.**

The certificate is valid
until 2017/04/01

2016/08/26

Date of initial certification



Dipl.-Ing. G. Weinmann
Head of Certification Body

Empowered by
 **BACnet**
INTEREST GROUP EUROPE

Annex to Certificate No. BAC-0210-01

The certification of the BACnet Implementations
DXR2.M11, DXR2.E12P, DXR2.M12P, etc.
of **Siemens Schweiz AG**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

BACnet Interoperability Building Blocks	
DS-RP-A	Data Sharing – Read Property – A
DS-RP-B	Data Sharing – Read Property – B
DS-RPM-A	Data Sharing – Read Property Multiple – A
DS-RPM-B	Data Sharing – Read Property Multiple – B
DS-WP-A	Data Sharing – Write Property – A
DS-WP-B	Data Sharing – Write Property – B
DS-WPM-A	Data Sharing – Write Property Multiple – A
DS-WPM-B	Data Sharing – Write Property Multiple – B
DS-COV-A	Data Sharing – COV – A
DS-COV-B	Data Sharing – COV – B
AE-N-I-B	Alarm and Event – Notification Internal – B
AE-ACK-B	Alarm and Event – Acknowledge Alarm – B
AE-ASUM-B	Alarm and Event – Alarm Summary – B
AE-ESUM-B	Alarm and Event – Event-Enrollment Summary – B
AE-INFO-B	Alarm and Event – Information – B
AE-EL-I-B	Alarm and Event Management – Event Log – Internal – B
T-VMT-I-B	Trending – Viewing and Modifying Trends Internal – B
T-ATR-B	Trending – Automated Trend Retrieval – B
DM-DDB-A	Device Management – Dynamic Device Binding – A
DM-DDB-B	Device Management – Dynamic Device Binding – B
DM-DOB-B	Device Management – Dynamic Object Binding – B
DM-DCC-B	Device Management – Device Communication Control – B
DM-TS-B	Device Management – Time Synchronization – B
DM-UTC-B	Device Management – UTC Time Synchronization – B
DM-RD-B	Device Management – Reinitialize Device – B
DM-BR-B	Device Management – Backup and Restore – B
DM-R-B	Device Management – Restart – B
DM-LM-B	Device Management – List Manipulation– B